



# 中国国家强制性产品认证证书



证书编号：2020322304000801

认证委托人名称： Longvale Limited  
 认证委托人地址： Lancaster Park, Needwood, Burton-upon-Trent, Staffordshire, DE13 9PD, United Kingdom  
 生产者名称： Longvale Limited  
 生产者地址： Lancaster Park, Needwood, Burton-upon-Trent, Staffordshire, DE13 9PD, United Kingdom  
 生产企业名称： Longvale Limited  
 企业地址： Lancaster Park, Needwood, Burton-upon-Trent, Staffordshire, DE13 9PD, United Kingdom

产品名称： 接近开关  
 系列、规格、型号： ES 系列, FS 系列  
 标准： GB 3836.1-2010、GB 3836.2-2010、GB 12476.1-2013、GB 12476.5-2013

上述产品符合强制性产品认证实施规则 CNCA-G23-01:2019 的要求，特发此证。

发证日期：2020 年 8 月 25 日      有效期至：2025 年 8 月 24 日

首次发证日期：2020 年 8 月 25 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



批 准：



## 上海仪器仪表自控系统检验测试所有限公司

<http://www.sitias.com.cn>

中国·上海·漕宝路103号200233

电话：+86 21 64510844

S 0000839



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



**CERTIFICATE NO: 2020322304000801**

**APPLICANT:** Longvale Limited  
**ADDRESS:** Lancaster Park, Needwood, Burton-upon-Trent, Staffordshire, DE13 9PD, United Kingdom

**MANUFACTURER:** Longvale Limited  
**ADDRESS:** Lancaster Park, Needwood, Burton-upon-Trent, Staffordshire, DE13 9PD, United Kingdom

**FACTORY:** Longvale Limited  
**ADDRESS:** Lancaster Park, Needwood, Burton-upon-Trent, Staffordshire, DE13 9PD, United Kingdom

**PRODUCTNAME:** Euroswitch  
**SERIES,SPECIFICATION,MODEL:** ES Series, FS Series  
**STANDARDS:** GB 3836.1-2010、GB 3836.2-2010、GB 12476.1-2013、GB 12476.5-2013

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

**Valid from:**August 25, 2020

**Valid until:** August 24, 2025

**Date of original certification:**August 25, 2020

**The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.**

This certificate is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



APPROVAL:

Xu JianPing



**Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.**

<http://www.sitilas.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0000483



# 中国国家强制性产品认证证书



证书编号: 2020322304000801

## 附件

产品名称: 接近开关

型号规格: ES *a b c d* - *e*, 其中:  
*a* 可选代码为: 1~6或SS  
*b* 可选代码为: 0, 3, A, B, C, D或F-Z  
*c* 可选代码为: 1或2  
*d* 可选代码为: 1, 1L, 2, 4L或5L  
*e* 可选代码为: A~F, 5K, 10K, (M), (N)或(N3)  
 FS *a b c d* - *e*, 其中:  
*a* 可选代码为: A~F, H~Q, CYL-B或CYL-C  
*b* 可选代码为: 0, 3, A, B, C, D或F-Z  
*c* 可选代码为: 1或2  
*d* 可选代码为: 1, 1L, 2, 4L或5L  
*e* 可选代码为: D, E, 5K, 10K, (M), (N)或(N3)  
 ES - HLS - *a*, 其中:  
*a* 可选代码为: 25d, 210d

防爆标志: Ex d IIC T3/T4/T6 Gb, Ex tD A21 IP66/IP67 T85°C/T135°C/T200°C

电气参数:

型号	电气参数
ES 系列	20W, 1A 或 3A
FS 系列	24V DC, 3A, 110V AC, 4A 或 240V AC, 2A
ES-SS 系列	24V DC, 100mA

批准:



## 上海仪器仪表自控系统检验测试所有限公司