



中国国家强制性产品认证证书



证书编号: 2020322304000873

认证委托人名称: Longvale Limited
 认证委托人地址: Lancaster Park, Needwood, Burton-upon-Trent, Staffordshire, DE13 9PD, United Kingdom
 生产者名称: Longvale Limited
 生产者地址: Lancaster Park, Needwood, Burton-upon-Trent, Staffordshire, DE13 9PD, United Kingdom
 生产企业名称: Longvale Limited
 生产企业地址: Lancaster Park, Needwood, Burton-upon-Trent, Staffordshire, DE13 9PD, United Kingdom

产品名称: 接近开关
 系列、规格、型号: ES 系列, FS 系列, VIP 系列, ESI 系列
 标 准: GB 3836.1-2010、GB 3836.4-2010、GB 12476.1-2013、GB 12476.4-2010

上述产品符合强制性产品认证实施规则 **CNCA-C23-01:2019** 的要求, 特发此证。

发证日期: 2020 年 8 月 31 日 有效期至: 2025 年 8 月 30 日

首次发证日期: 2020 年 8 月 31 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批 准: 



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322304000873

APPLICANT: Longvale Limited
ADDRESS: Lancaster Park, Needwood, Burton-upon-Trent, Staffordshire, DE13 9PD, United Kingdom

MANUFACTURER: Longvale Limited
ADDRESS: Lancaster Park, Needwood, Burton-upon-Trent, Staffordshire, DE13 9PD, United Kingdom

FACTORY: Longvale Limited
ADDRESS: Lancaster Park, Needwood, Burton-upon-Trent, Staffordshire, DE13 9PD, United Kingdom

PRODUCTNAME: Euroswitch

SERIES,SPECIFICATION,MODEL: ES Series, FS Series, VIP Series, ESI Series

STANDARDS: GB 3836.1-2010、GB 3836.4-2010、GB 12476.1-2013、GB 12476.4-2010

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from:August 31, 2020

Valid until: August 30, 2025

Date of original certification:August 31, 2020

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Xu JianPing



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.



中国国家强制性产品认证证书



SITIiAS
Worldwide Access

证书编号: 2020322304000873

附件

产品名称: 接近开关

型号规格:

ES *a b c d* - *e*, 其中:

a 可选代码为: 1, 2, 3, 4, 5, 6, 2S, 44, BZ18, SS, HLS-25i或HLS210i

b 可选代码为: 2, E或F-Z

c 可选代码为: 1或2

d 可选代码为: 1, 1L, 2或4L

e 可选代码为: A~F, FP, LFM, 5K, 10K, SE, W, WL, WLR, WLRT, (M), (N), (3N), V2-3, V2-4, V5-3, V5-4, V3-3或V3-4

FS *a b c d* - *e*, 其中:

a 可选代码为: A~F, H~R或CYL

b 可选代码为: 2, E或F-Z

c 可选代码为: 1或2

d 可选代码为: 1, 1L, 2或4L

e 可选代码为: A, B, D, E, FP, LFM, 5K, 10K, SE, W, WL, WLR, WLRT, (M), (N), (3N), V2-3, V2-4, V5-3, V5-4, V3-3或V3-4

a - VIP - *b*, 其中:

a 可选代码为: MI或MS

b 可选代码为: 4或1

ESI - VDHA - *a*, 其中:

a 可选代码为: 1035, 700, 450

防爆标志:

Ex ia IIC T3/T4/T6 Ga, Ex iaD 20 T75/T85/T135/T140/T185/T200

电气参数:

产品最大电气参数为 $U_i=30V$, $I_i=250mA$, $P_i=1.3W$, $C_i=0$ 或 $120pF/m$, $L_i=0$ 或 $0.7\mu H/m$ 。

批准:



上海仪器仪表自控系统检验测试所有限公司